



中国国家强制性产品认证证书

证书编号: 2017010305978971

委托人名称、地址

创景传感工业(惠州)有限公司
广东省惠州市仲恺高新技术产业开发区平南工业园惠风西二路6号3-4楼

生产者(制造商)名称、地址

Crouzet Automatismes SAS
ZA De La Plaine - 10 rue du Docteur Abel - 26027 Valence cedex France

生产企业名称、地址

CROUZET SA
Lot 16 - Zone Industrielle Sidi Marouf - CP 20280 Casablanca Morocco

产品名称和系列、规格、型号

控制开关

83170, 83169, 83589, 83581, 83576(型号解释详见附件);
Ui:250V;Ith:12.5A(831700), 12A(83576), 6A(831694, 831698, 831699, 831704, 831708, 831709)
, 8A(831690, 83589, 83581); AC-15:Ue/Ie:AC250V/2.5A;DC-13:Ue/Ie:DC250V/0.1A;
IP40(83170, 83576), IP67(83169, 83581, 83589)

产品标准和技术要求

GB/T 14048.5-2008

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求,
特发此证。

发证日期: 2017年06月26日 有效期至: 2022年06月26日
证书有效期内本证书的有效性依据发证机构的定期监督获得保持。
本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任:



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2017010305978971

NAME AND ADDRESS OF THE APPLICANT

InnoVista sensors industry (Huizhou) Ltd
3rd and 4th Floor, No.6,Huifeng West 2nd Road, Pingnan Industrial Park,Zhongkai Hi-tech Industrial
Development Zone,Huizhou,Guangdong

NAME AND ADDRESS OF THE MANUFACTURER

Crouzet Automatismes SAS
ZA De La Plaine – 10 rue du Docteur Abel – 26027 Valence cedex France

NAME AND ADDRESS OF THE FACTORY

CROUZET SA
Lot 16 – Zone Industrielle Sidi Marouf – CP 20280 Casablanca Morocco

PRODUCT NAME, MODEL AND SPECIFICATION

Control Switch

83170,83169,83589,83581,83576; Ui:250V;lth:12.5A(831700),12A(83576),6A(831694,831698,831699,831704,831
708,831709),8A(831690,83589,83581); AC-15:Ue/Ie:AC250V/2.5A;DC-13:Ue/Ie:DC250V/0.1A; IP40(83170,8357
6),IP67(83169,83581,83589)

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.5-2008

This is to certify that the above mentioned product(s) complies with the requirements of
implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Jun.26,2017

Valid until: Jun.26,2022

The validity of the certificate is subject to positive result of the regular follow up inspection by
issuing certification body until the expiry date.

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附录:

第 1 页 共 1 页

证书编号: 2017010305978971

纸号: 1729128

型号解释:

XX	XXX	X	XX	Example
Switches family	Version	Type	Customer special code	
83	169	0 Standard	XX	83169002
		4 Reduced differential travel		83169405
		8 Dual-current		83169802
		9 Dual-current reduced differential travel		83169907
	170	0 Standard		83170005
		1 Continuing Type 0		83170107
		4 Low force		83170402
		8 Dual-current		83170805
		9 Dual-current - Low force		83170965
	576	Seld ajustabled large travel Limitswitch		83576002
	581	0 Standard - Plunger		83581001
		1 Standard - Roller Plunger		83581101
		8 Low energy load - Plunger		83581801
		9 Low energy load - Roller Plunger		
	589	0 Standard		83589031
		8 Low energy load		83589801

注: 此附录与证书同时使用时有效。



主任:



中国质量认证中心



中国国家强制性产品认证证书

证书编号: 2017010305981443

委托人名称、地址

创景传感工业(惠州)有限公司
广东省惠州市仲恺高新技术产业开发区平南工业园惠风西二路6号3-4楼

生产者(制造商)名称、地址

Crouzet Automatismes SAS
ZA De La Plaine - 10 rue du Docteur Abel - 26027 Valence cedex France

生产企业名称、地址

Crouzet Automatismes SAS
ZA De La Plaine - 10 rue du Docteur Abel - 26027 Valence cedex France

产品名称和系列、规格、型号

控制开关

83170, 83169, 83589, 83581, 83576(型号解释详见附件);
Ui:250V;Ith:12.5A(831700), 12A(83576), 6A(831694, 831698, 831699, 831704, 831708, 831709)
, 8A(831690, 83589, 83581); AC-15:Ue/Ie:AC250V/2.5A;DC-13:Ue/Ie:DC250V/0.1A;
IP40(83170, 83576), IP67(83169, 83581, 83589)

产品标准和技术要求

GB/T 14048.5-2008

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求,
特发此证。


发证日期: 2017年07月04日 有效期至: 2022年07月04日
证书有效期内本证书的有效性依据发证机构的定期监督获得保持。
本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任:



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2017010305981443

NAME AND ADDRESS OF THE APPLICANT

InnoVista sensors industry (Huizhou) Ltd
3rd and 4th Floor, No.6,Huifeng West 2nd Road, Pingnan Industrial Park,Zhongkai Hi-tech Industrial
Development Zone,Huizhou,Guangdong

NAME AND ADDRESS OF THE MANUFACTURER

Crouzet Automatismes SAS
ZA De La Plaine – 10 rue du Docteur Abel – 26027 Valence cedex France

NAME AND ADDRESS OF THE FACTORY

Crouzet Automatismes SAS
ZA De La Plaine – 10 rue du Docteur Abel – 26027 Valence cedex France

PRODUCT NAME, MODEL AND SPECIFICATION

Control Switch

83170,83169,83589,83581,83576; Ui:250V;lth:12.5A(831700),12A(83576),6A(831694,831698,831699,831704,831
708,831709),8A(831690,83589,83581); AC-15:Ue/Ie:AC250V/2.5A;DC-13:Ue/Ie:DC250V/0.1A; IP40(83170,8357
6),IP67(83169,83581,83589)

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.5-2008

This is to certify that the above mentioned product(s) complies with the requirements of
implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Jul.04,2017

Valid until: Jul.04,2022

The validity of the certificate is subject to positive result of the regular follow up inspection by
issuing certification body until the expiry date.

The certificate information is available through CNCA's website: www.cnca.gov.cn




President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附录:

第 1 页 共 1 页

证书编号: 2017010305981443

纸号: 1738880

型号解释:

XX	XXX		X		XX	Example
Switches family	Version		Type		Customer special code	
83	169	Sealed Microswitch	0	Standard	XX	83169002
			4	Reduced differential travel		83169405
			8	Dual-current		83169802
			9	Dual-current reduced differential travel		83169907
	170	Microswitch	0	Standard		83170005
			1	Continuing Type 0		83170107
			4	Low force		83170402
			8	Dual-current		83170805
						83170840
			9	Dual-current - Low force		83170965
	576	Seld ajustabled large travel Limitswitch	0			83576002
	581	Limitswitch	0	Standard - Plunger		83581001
			1	Standard - Roller Plunger		83581101
			8	Low energy load - Plunger		83581801
			9	Low energy load - Roller Plunger		
	589	Limitswitch	0	Standard		83589031
			8	Low energy load		83589801

注: 此附录与证书同时使用时有效。



主 任:



中国质量认证中心