



中国国家强制性产品认证证书

证书编号: 2016010305917103

委托人名称、地址

创景传感工业(惠州)有限公司
广东省惠州市仲恺高新技术产业开发区平南工业园惠风西二路6号3楼

生产者(制造商)名称、地址

创景传感工业(惠州)有限公司
广东省惠州市仲恺高新技术产业开发区平南工业园惠风西二路6号3楼

生产企业名称、地址

创景传感工业(惠州)有限公司
广东省惠州市仲恺高新技术产业开发区平南工业园惠风西二路6号3楼

产品名称和系列、规格、型号

微动开关

8326(型号解释详见附件);

Ui:250V;Ith:10A(83260), 20A(83261, 83263), 25A(83262), 15A(83264), 7.5A(83265);

AC-15:Ue/Ie:AC250V/4A(83261, 83263), AC250V/8A(83262), AC250V/6A(83264,

83260), AC250V/1A(83265), AC250V/0.04A(83268, 83269);

DC-13:Ue/Ie:DC250V/0.2A(83261, 83262, 83263, 83264, 83265, 83268, 83269);DC30V/10.1A, DC1
20V/0.3A(83260);IP40

产品标准和技术要求

GB/T 14048.5-2008

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求,
特发此证。

发证日期: 2017年05月27日 有效期至: 2021年12月20日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2016年12月20日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任:



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2016010305917103

NAME AND ADDRESS OF THE APPLICANT

InnoVista Sensors Industry (Huizhou) Ltd.

3rd Floor, No. 6, Huifeng West 2nd Road, Pingnan Industrial Park - Zhongkai Hi-tech Industrial Development Zone - Huizhou, Guangdong, China.

NAME AND ADDRESS OF THE MANUFACTURER

InnoVista Sensors Industry (Huizhou) Ltd.

3rd Floor, No. 6, Huifeng West 2nd Road, Pingnan Industrial Park - Zhongkai Hi-tech Industrial Development Zone - Huizhou, Guangdong, China.

NAME AND ADDRESS OF THE FACTORY

InnoVista Sensors Industry (Huizhou) Ltd.

3rd Floor, No. 6, Huifeng West 2nd Road, Pingnan Industrial Park - Zhongkai Hi-tech Industrial Development Zone - Huizhou, Guangdong, China.

PRODUCT NAME, MODEL AND SPECIFICATION

Micro-switch

8326; Ui:250V;Ith:10A(83260),20A(83261,83263),25A(83262),15A(83264),7.5A(83265); AC-15:Ue/Ie:AC250V/4A(83261,83263),AC250V/8A(83262),AC250V/6A(83264, 83260),AC250V/1A(83265),AC250V/0.04A(83268,83269); DC-13:Ue/Ie:DC250V/0.2A(83261,83262,83263,83264,83265,83268,83269);DC30V/10.1A,DC120V/0.3A(83260);IP 40

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.5-2008

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: May.27,2017

Valid until: Dec.20,2021

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Dec.20,2016

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附录:

第 1 页 共 1 页

证书编号: 2016010305917103

纸号: 1719472

型号解释:

产品代码/product code:

Model/ Type	X					X		Custo mer special code	Example
	Current code					Type code			
	#	Ampere (A)	Force Max,g	NO/NC contact	Movable plate contact	#	Type		
8326 (IP40)	0	6/8	400	AgNi10	AgNi10	7	B/C	00-99	83260701
	1	16	400	AgNi10+Cu	AgNi10	0	C	00~99	83261011
	2	21/25	400	AgNi10/FAg	AgNi10/FAg	1	C		83262011
	3	16	100	AgNi10+Cu	AgNi10	5	2 same type micro-switc hes		83263011
	4	8	50	AgNi10+Cu	AgNi10	6	B		83264011
	5	5	25	AgNi10+Cu	AgNi10	7	B		83265011
	8	0.001~5	200	Cu+Au plated/ AgNi10+Cu+A u plated	Cu+Au plated/ AgNi10+Au plated	8	A		83268107
	9	0.1	25	Cu+Au plated	Cu+Au plated	9	A		83269011

注: 此附录与证书同时使用时有效。



主 任:



中国质量认证中心